

The following sample(s) was/were submitted and identified on behalf of the client as:

Sample Description : WPC DOOR  
 SGS Ref No. : SDHL1803005604FB  
 Sample Receiving Date : Mar. 23, 2018  
 Test Performing Date : Mar. 23, 2018 to Apr. 09, 2018  
 Test Performed : Selected test(s) as requested by applicant  
 Test Result(s) : For further details, please refer to the following page(s)

**Test Result Summary**

Test(s) Requested	Result(s)
EN 13501-1:2007+A1:2009 Fire classification of construction products and building elements-Part 1: Classification using data from reaction to fire tests	Classification: D-s3, d0
<b>Summary:</b>	
1. For further details, please refer to the following page(s).	

Signed for and on behalf of  
 Xiamen Branch, SGS-CSTC Co., Ltd.



Sharky Xia  
 Approved Signatory



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of the Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not constitute parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) stated and such sample(s) are retained for 30 days only.  
 Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1663, or email: [CS@sgs.com](mailto:CS@sgs.com)  
 No. 21 Nanjing Road, Songlin Tech Industrial Zone, Xiamen Fujian Province, China 361101 | (86-592) 576637 | (86-592) 576640 | [www.sgs.com.cn](http://www.sgs.com.cn)